# ☐ ESBF670 Recessed Emergency Shower, Exposed Shower Head

**Application:** Recessed emergency shower with ceiling mounted exposed shower head. Recessed shower conserves valuable floor space, while eliminating the clutter and obstruction created by conventional shower equipment. Unit can be installed in either a corridor or a lab room, close to where accidents might occur.

**ADA Compliance:** When installed at recommended mounting heights, unit complies with ADA requirements for accessibility by handicapped persons.

**Shower Head:** 10" diameter stainless steel. Furnished with vertical supply pipe and ceiling escutcheon for mounting shower head at desired height below finished ceiling.

**Valve:** 1" IPS brass stay-open ball valve with stainless steel "panic bar." Pulling bar down activates shower; shower remains in operation until bar is returned to original closed position. Furnished with stainless steel access panel and 1" IPS unions for valve.

**Pipe and Fittings:** Exposed pipe and escutcheon are brushed stainless steel.

**Supply:** 1" NPT female inlet.

**Sign:** ANSI-compliant identification sign.

**U.S. Patent 5,768,721**

## Available Options

- ☐ **FC20** Regulates shower flow rate to 20 GPM.
- ☐ **AP250-065** Modesty curtain for wall mounting.
- ☐ **AP280-235** Electric Light and Alarm Horn. Flashing light/alarm horn unit is recess mounted in finished wall. Light is illuminated and horn sounds when shower is activated. Includes additional leads for remote monitoring.
- ☐ **TMV** AP3800 thermostatic mixing valve precisely blends hot and cold water to deliver tepid water as required by ANSI Z358.1-2014.

*Note: Shown with optional AP280-235 electric light and alarm horn unit (sold separately).*

WaterSaver
701 W Erie St
Chicago, IL 60654

312 666 5500 TELEPHONE
312 666 5501 FACSIMILE
wsflab.com

Listed 8116. Units have been tested to and comply with ANSI Z358.1-2014 and the Uniform Plumbing Code.

ETL Listed 101496. Units have been tested to and comply with ANSI Z358.1-2014.

WaterSaver



## ☐ ESBF670 Recessed Emergency Shower, Exposed Shower Head

NOTES:
1. A MINIMUM OF 4 1/8" IS REQUIRED FROM FINISHED WALL SURFACE TO REAR OF WALL CAVITY TO ACCOMODATE UNIT.
2. STANDARD DIMENSION FROM SHOWER HEAD TO WALL IS 24". WHEN UNIT IS USED IN BARRIER-FREE APPLICATIONS, DIMENSION SHOULD BE 36".
3. U.S. PATENT NO. 5,768,721.
4. PROVIDE 7 1/4" X 14 1/2" CUTOUT IN WALL FOR HOUSING INSTALLATION.




Sign Included

THIS SPACE FOR ARCHITECT/ENGINEER APPROVAL

Due to continuing product improvement, the information contained in this document is subject to change without notice. All dimensions are ± 1/4" (6mm). rev. 0315

WaterSaver
701 W Erie St
Chicago, IL 60654

312 666 5500 TELEPHONE
312 666 5501 FACSIMILE
wsflab.com

Listed 8116. Units have been tested to and comply with ANSI Z358.1-2014 and the Uniform Plumbing Code.

ETL Listed 101496. Units have been tested to and comply with ANSI Z358.1-2014.